DOE/OE Transmission Reliability Program

Load as a Resource: Building Loads for Ancillary Services

Duncan Callaway and Jason MacDonald


dcallaway@lbl.gov jsmacdonald@lbl.gov Lawrence Berkeley National Lab

> June 10-11, 2015 Washington, DC






Overall Program Objectives








Looking Back – IT/Communications



Motivation (2011-2013):

- Standardized protocol for *DR for AS*
- Evaluation of comm.latencies






Accomplishments:

- OpenADR 2.0b developed in collaboration with OpenADR Alliance, vetted by ISO/RTO Council [FY11]
 - NIST National Smart Grid Standard, IEC-standard
 - >50 2.0b certified products commercially available
- Evaluated OpenADR 2.0b communication latency:
 - in simulation [FY11] and demonstration with industry partner, IPKeys
 (MacDonald et al, 2014)




Looking Back – DR for AS Economics



Motivation

- Potential revenue for DR for AS?
- What are the costs? Boxplots of MCP for Up Regulation (DA) Summer



Accomplishments / Key Results:

- ISO/RTO AS market comparison
 - AS Opportunity between \$5-26.5 / kW-mo with 24-7 participation
 - Publication received a best paper award (MacDonald et al, 2012)
- Compiled Enablement Costs for DR
 - ~\$2000/site for small commercial (Kiliccote et al, 2014)





Looking Back – DR "Generator"



Motivation

- **Demonstrate Capability**
- Quantify Accuracy + Response Time








PJM Regulation D Self Test

Accomplishments / Key Results:

- Jemonstrated DR for Sync ness.

 Industry Partners: Wal-Mart and IPKeys 10.75 Demonstrated DR for Sync Reserve
- Demonstrated DR for Regulation
 - Industry Partners: Schneider & IPKeys
 - HVAC fan w/ variable frequency drive

Published: (MacDonald et al, 2014)







Taking stock: Key unknowns

- We understand enablement costs and market potential, but are there ongoing opportunity costs?
 - If buildings are batteries, what's round trip efficiency?
- Partner tests: VFD tracking accuracy ~ 90% and very low latency. But what about total building systems? Need:
 - a perfect baseline
 - validated building models
 - state of the art control
 - End-to-end tracking of communications and actuation times
- If reserves are from space conditioning, how do occupant comfort and reserve offering interact?







LBNL FLEXLAB


- No occupants
- Four pairs of identical bays
- Variable speed chiller and fan
- Validated physics-based building models
- Extensive monitoring and submetering
- Transparent building energy management system
 - facilitates integration of advanced building control
- Access to PJM RegA and RegD signals in real time





Looking forward -- current stage in R&D cycle

FLEXLAB experiments: Second bay serves as "perfect" baseline (for computing opportunity cost and tracking performance)







Hierarchical control scheme

Reserve scheduling & allocation

Reserve market

ISO

Level 1: Aggregator

Utility company

HVAC control & AGC tracking

Building b

Plant


Level 2: MPC

Level 3: Feedback control






Hierarchical control scheme









Looking forward: objectives

- FLEXLAB experiments complete this month
- Analysis complete by October
 - Quantify round trip efficiency of reg provision
 - Evaluate forecasting, optimization and control tool: accuracy
 - Quantify end-to-end latency, from PJM reg signal to change in power consumption
- Deliverables complete by January





Looking forward: Deliverables

- Conference publication on round trip reserve efficiency (operating cost) submitted November
- Draft technical report in December
- Journal publication evaluating forecasting tools, robust optimization and real time control submitted in Jan 2016





Risk Factors

- PJM communications hardware and software integration in a very short timeframe
 - Many communicating components in architecture
 - Could have controls read directly from historical data
- First experiment of this nature in FLEXLAB
 - Buildings and sensors may not perform as expected
 - Follow-on experiments in October, if needed
- Second FLEXLAB bay may not be perfect baseline
 - Use regression models to solve the problem





Potential follow-on work

- Work with other ISO's regulation signals
- Whole building demonstration w/ industrial partners
- Investigate tools to alleviate Landis telemetry requirements



- Quantify and minimize post-reserve actuation dynamics ("rebound")
- Entire building plant control
 - Current experiments focus on supply fan
 - Chiller can also respond
 - Requires better building models, but yields more capacity





Looking Back – Referenced Pubs

- MacDonald, Jason, Sila Kiliccote, Jim Boch, Jonathan Chen, Robert Nawy. "Commercial Building Loads Providing Ancillary Services in PJM." ACEEE Summer Study on Energy Efficiency in Buildings 2014. Asilomar Conference Center, Pacific Grove, CA, 2014
- MacDonald, Jason, Peter Cappers, Duncan S. Callaway, and Sila Kiliccote. "Demand Response Providing Ancillary Services A Comparison of Opportunities and Challenges in the US Wholesale Markets." In Grid-Interop 2012. Irving, TX, 2012.
- Kiliccote, Sila, Steven Lanzisera, Anna Liao, Oren Schetrit, Mary Ann Piette. "Fast DR: Controlling Small Loads over the Internet." ACEEE Summer Study on Energy Efficiency in Buildings 2014. Asilomar Conference Center, Pacific Grove, CA, 2014.





Thank you



